



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5181CO0550

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
Distributor <i>Vertreiber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
Product Category <i>Produktart</i>	Greasing and sealing materials: Coatings for steel tubes (5181)
Product description <i>Produktbezeichnung</i>	Heat-shrinkable wraparound sleeve
Model <i>Modell</i>	DEKOTEC® MTS-55
Test reports <i>Prüfberichte</i>	Laboratory control test: 21-01490-KP03 from 13.07.2023 (EBI) Type testing: 12/317/5180/1 from 03.05.2013 (EBI)
Test basis <i>Prüfgrundlagen</i>	DIN EN ISO 21809-3 (01.08.2016)

Date of Expiry / File No. 03.05.2028 / 23-0449-GNV
Ablaufdatum / Aktenzeichen

26.07.2023 Kir A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
DEKOTEC® MTS-55	Permanent operating temperature: ...50 °C Designation according to standard: coating DIN EN ISO 21809-3; type 14A-1 Type: 14A-1	

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

Application: Warm applied heat shrinkable sleeve

DVGW