



CERT

# DIN-DVGW type examination certificate

## DIN-DVGW-Baumusterprüfzertifikat

NG-5180CS0315

Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
<b>Distributor</b> <i>Vertreiber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
<b>Product Category</b> <i>Produktart</i>	greasing and sealing materials: Protection tape against corrosion (5180)
<b>Product Description</b> <i>Produktbezeichnung</i>	Protection tape against corrosion
<b>Model</b> <i>Modell</i>	DENSOLEN®-AS40 PLUS/-R20 HT mit DENSOLEN®-MT25 Primer
<b>Test Reports</b> <i>Prüfberichte</i>	laboratory control test: 21-01497-KP02- from 13.07.2022 (EBI) supplement test: 17/335/5180/3 from 08.01.2018 (EBI) type testing: 16/251/5180/13_1 from 14.06.2017 (EBI)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	DIN EN 12068 (01.03.1999) DIN 30672 (01.12.2000)

**Date of Expiry / File No.** 14.06.2027 / 22-0361-GNV  
**Ablaufdatum / Aktenzeichen**

12.10.2022 Fk A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-05

DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

<b>Type</b> <i>Typ</i>	<b>Technical Data</b> <i>Technische Daten</i>	<b>Remarks</b> <i>Bemerkungen</i>
DENSOLEN®-AS40 PLUS/-R20 HT mit DENSOLEN®-MT25 Primer	stress-class: C permanent operating temperature: up to +50 °C designation according to standard: coating DIN EN 12068-C 50 resp. DIN 30672-C 50	

**Hints of Utilization / Remarks****Verwendungshinweise / Bemerkungen**

application: 4 (2+2) layers to be wrapped cold on top of primer coat "MT 25"