



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NV-5180CN0381

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas and water supply <i>Produkte der Gas- und Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
Distributor <i>Vertreiber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
Product Category <i>Produktart</i>	greasing and sealing materials: Protection tape against corrosion (5180)
Product Description <i>Produktbezeichnung</i>	corrosion protection system consisting of Densolen-primer HT, Densolen-tape AS50 (2 layers) and Densolen-tape R20HT (2 layers)
Model <i>Modell</i>	Densolen-System AS50-R20HT mit Primer HT
Test Reports <i>Prüfberichte</i>	laboratory control test: 21-01291-KP02- from 13.07.2022 (EBI) laboratory control test: 17/024/5180/21 from 20.03.2017 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 12068 (01.03.1999)

Date of Expiry / File No. 12.12.2027 / 22-0361-GNV
Ablaufdatum / Aktenzeichen

12.10.2022 Fk A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Densolen-System AS50-R20HT mit Primer HT	stress-class: C permanent operating temperature: up to +50 °C designation according to standard: coating EN 12068-C 50 L	

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

Application: corrosion protection system for cold application in 4 (2/2) layers on the pre-coating