



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NV-5180CL0054

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas and water supply <i>Produkte der Gas- und Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
Distributor <i>Vertreiber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
Product Category <i>Produktart</i>	greasing and sealing materials: Protection tape against corrosion (5180)
Product Description <i>Produktbezeichnung</i>	Single tape corrosion prevention coating with primer
Model <i>Modell</i>	DENSOLEN®-AS50
Test Reports <i>Prüfberichte</i>	type testing: 09/308/5180/2 from 04.03.2010 (EBI) laboratory control test: 19/035/5180/018 from 01.04.2020 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN 30672 (01.12.2000) DIN EN 12068 (01.03.1999)

Date of Expiry / File No. 04.03.2025 / 20-0227-GNV
Ablaufdatum / Aktenzeichen

01.04.2020 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
DENSOLEN®-AS50	stress-class: B permanent operating temperature: max. +50 °C	

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

application: cold applied corrosion protection coating with 2 layers to be wrapped on top of primer coat
standard indication: coating EN 12068-B 50 respectively DIN 30672-B 50

DWG