



**CERT**

# DIN-DVGW type examination certificate

## DIN-DVGW-Baumusterprüfzertifikat

**NV-5180BN0071**

Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of gas and water supply <i>Produkte der Gas- und Wasserversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
<b>Distributor</b> <i>Vertreiber</i>	DENSO GmbH Felderstraße 24, D-51371 Leverkusen
<b>Product Category</b> <i>Produktart</i>	greasing and sealing materials: Protection tape against corrosion (5180)
<b>Product Description</b> <i>Produktbezeichnung</i>	two-tape corrosion prevention coating with primer
<b>Model</b> <i>Modell</i>	DENSOLEN®-N60/-S20 mit Voranstrich DENSOLEN®-HT Primer
<b>Test Reports</b> <i>Prüfberichte</i>	laboratory control test: 21-01264-KP02- from 14.06.2022 (EBI) type testing: VA KU 25 924 from 24.02.2017 (TGM)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	DIN EN 12068 (01.03.1999) DIN 30672 (01.12.2000)

**Date of Expiry / File No.** 06.03.2027 / 22-0361-GNV  
**Ablaufdatum / Aktenzeichen**

11.10.2022 Fk A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
DENSOLEN®-Zweibandsystem N60/-S20	stress-class: C permanent operating temperature: +50 °C designation according to standard: coating EN 12068-C 50 / DIN 30672-C 50	

**Hints of Utilization / Remarks*****Verwendungshinweise / Bemerkungen***

Application: corrosion protection system for cold application in 4 (2/2) layers on the pre-coating