



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NV-5180AO0703

Registration Number
Registriernummer

| | |
|---|---|
| Field of Application <i>Anwendungsbereich</i> | products of gas and water supply <i>Produkte der Gas- und Wasserversorgung</i> |
| Owner of Certificate <i>Zertifikatinhaber</i> | DENSO GmbH Felderstraße 24, D-51371 Leverkusen |
| Distributor <i>Vertreiber</i> | DENSO GmbH Felderstraße 24, D-51371 Leverkusen |
| Product Category <i>Produktart</i> | Greasing and sealing materials: Protection tape against corrosion (5180) |
| Product description <i>Produktbezeichnung</i> | Corrosion prevention tape based on petrolatum |
| Model <i>Modell</i> | DENSO®-Plast |
| Test reports <i>Prüfberichte</i> | Laboratory control test: 21-01256-KP03 from 21.06.2023 (EBI) Type testing: 23/107/5180/1 from 09.12.2013 (EBI) |
| Test basis <i>Prüfgrundlagen</i> | DIN 30672-1 (01.05.2019) DIN EN 12068 (01.03.1999) |



Date of Expiry / File No. 31.08.2028 / 23-0449-GNV
Ablaufdatum / Aktenzeichen

70009-04-A-DE

24.07.2023 Kir A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

| Type <i>Typ</i> | Technical Data <i>Technische Daten</i> | Remarks <i>Bemerkungen</i> |
|---------------------------|---|--------------------------------------|
| DENSO®-Plast | Stress class: A Permanent operating temperature: up to +30 °C Designation according to standard: Coating EN 12068-A 30 respectively DIN 30672-A 30 | |

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

Application with 75 % overlap (3 layers) to applied cold